

From: [Fred Kemp](#)
To: [Hould, Hannah](#)
Subject: RE: FW: @home 5 Bridge Street, Salisbury SP1 2ND
Date: 30 April 2019 08:45:25

Hi Hannah,

The issue here is that unless the storage issue is resolved the occupancy will be reduced to 60 persons, on the basis, of there being only one viable exit.

Therefore I would recommend that the storage issue is resolved.

Regards,

Fred

Fred Kemp GIFireE
Fire Safety Inspector.
Telephone: 01722 69 1334
E-mail: fred.kemp@dwfire.org.uk

Please note my working hours are Monday and Tuesday 0800-1700

-----Original Message-----

From: Hould, Hannah <Hannah.Hould@wiltshire.gov.uk>
Sent: 29 April 2019 17:24
To: Fred Kemp <Fred.Kemp@dwfire.org.uk>
Subject: FW: FW: @home 5 Bridge Street, Salisbury SP1 2ND

FYI

-----Original Message-----

From: Louella Adamson [REDACTED]
Sent: 29 April 2019 17:23
To: Hould, Hannah
Subject: Re: FW: @home 5 Bridge Street, Salisbury SP1 2ND

Okay, great. There is no obstruction and the shed isn't my responsibility.

Kind Regards

Louella Adamson
Top Dog
@home Salisbury ltd
[REDACTED]
athomesalisbury.com
fb @homesalisbury ig home_salisbury t @home_salisbury

On 29/04/2019 17:18, Hould, Hannah wrote:

> Louella,
>
> It is comments from the Fire Authority, who are a responsible
> authority. They are advising you as part of the review consultation
> period.
>
> Kind regards
>
> Hannah Hould
> Public Protection Officer (Licensing)
>

> Wiltshire Council
> Bourne Hill
> Salisbury
> Wiltshire
> SP1 3UZ
>
> Email: hannah.hould@wiltshire.gov.uk
> Direct Dial: 01722 434414
> Internal: 54414

> -----Original Message-----

> From: Louella Adamson [REDACTED]
> Sent: 29 April 2019 16:57
> To: Hould, Hannah
> Subject: Re: FW: @home 5 Bridge Street, Salisbury SP1 2ND

> What does this mean?

> ---

> Kind Regards

> Louella Adamson
> Top Dog
> @home Salisbury ltd
> [REDACTED]
> athomesalisbury.com
> fb @homesalisbury ig home_salisbury t @home_salisbury

> On 29/04/2019 15:36, Hould, Hannah wrote:

>> Hi Louella,

>>
>> Please find email below from the Fire Authority relating to the
>> review application.

>> Kind regards

>> HANNAH HOULD

>> PUBLIC PROTECTION OFFICER (LICENSING)

>> Wiltshire Council

>> Bourne Hill

>> Salisbury

>> Wiltshire

>> SP1 3UZ

>> Email: hannah.hould@wiltshire.gov.uk

>> Direct Dial: 01722 434414

>> Internal: 54414

>>

>> FROM: Fred Kemp [<mailto:Fred.Kemp@dwfire.org.uk>]
>> SENT: 29 April 2019 14:51
>> TO: Hould, Hannah
>> SUBJECT: @home 5 Bridge Street, Salisbury SP1 2ND
>>
>> Hi Hannah,
>>
>> Following our discussion last week regarding the above premises, I
>> visited it on 29/04/19 and was unable to gain access. There were no
>> visible obstructions internally and both exit routes were also
>> useable and unobstructed. There was light debris around the rear exit
>> and the storage cupboards should be either emptied and sealed shut or
>> constructed to be lockable and provide 30 minutes fire resistance.
>>
>> Regards,
>>
>> Fred.
>>
>> Fred Kemp GIFireE
>>
>> Fire Safety Inspector.
>>
>> Telephone: 01722 69 1334
>>
>> E-mail: fred.kemp@dwfire.org.uk
>>
>> PLEASE NOTE MY WORKING HOURS ARE MONDAY AND TUESDAY 0800-1700
>>
>> Internet e-mail is not to be regarded as a secure means of
>> communication. Dorset & Wiltshire Fire and Rescue Service monitors
>> all Internet e-mail activity and content. This communication and any
>> files transmitted with it is intended for the person(s) to whom it is
>> addressed and may be confidential, legally privileged and protected
>> in law. Unauthorised use, disclosure, copying or distribution is
>> prohibited. Please notify the sender if received in error then delete
>> it from your system. Opinions expressed in this communication may not
>> be official policy. Whilst every effort is made to carefully choose
>> websites that we may provide links to, Dorset & Wiltshire Fire and
>> Rescue Service cannot guarantee the standards of these sites. Virus
>> Disclaimer: Dorset & Wiltshire Fire and Rescue Service takes all
>> reasonable steps to ensure electronic communications are protected
>> from virus infection but cannot accept any liability for any loss or
>> damage sustained as a result of software viruses. Intended recipients
>> are responsible for carrying out virus checking as is necessary
>> before opening any attachments.
>>
>> -----
>>
>> This email originates from Wiltshire Council and any files
>> transmitted with it may contain confidential information and may be
>> subject to Copyright or Intellectual Property rights. It is intended
>> solely for the use of the individual or entity to whom they are
>> addressed. If you have received this email in error please notify the
>> sender and delete the email from your inbox. Any disclosure,
>> reproduction, dissemination, modification and distribution of the
>> contents of the email is strictly prohibited. Email content may be
>> monitored by Wiltshire Council to ensure compliance with its policies
>> and procedures. No contract is intended by this email, and any
>> personal opinions expressed in this message are those of the sender
>> and should not be taken as representing views of Wiltshire Council.
>> Please note Wiltshire Council utilises anti-virus scanning software