

TLC Solicitors
One Redcliffe Street
Bristol
BS1 6TP

Please ask for: Julian Hancock

Fire Safety Inspector

Our reference: BL220665

Date: 29th October 2014

FAO Barry Richards

Dear Sir

Application for Premises Licence

Licensing Act 2003 Regulatory Reform (Fire Safety) Order 2005

Premises: SN15, 17 Station Hill, Chippenham SN15 1EQ

I refer to your application dated 20th October 2014 for a licence for the above premises.

A further inspection of the premises has been carried out on 29th October 2014 and, based on the findings, I write to inform you that the Fire Authority has no adverse comments to make.

Whilst on site it was noted that not all the issues in the preliminary Fire Risk Assessment report provided by Mr Tombs have been resolved. I understand that Mr White is contacting Mr Tombs to clarify these issues.

Articles 9 & 11 of The Regulatory Reform (Fire Safety) Order 2005 require that a suitable and sufficient fire risk assessment is completed and the significant findings are recorded.

Further guidance can be found in the "Fire Safety – Risk Assessment" publication for this premises type, available from most bookshops or as a free download from the Communities and Local Government website.

I take this opportunity to remind you that fire safety is a dynamic process to be considered on a daily basis, and the assessment of fire risk should be constantly under review and updated as required, especially where the risk in the premises has been affected by alterations, changes in procedures, use or occupancy.

Yours faithfully

J. P. Hancock Fire Safety Inspector

cc John White, Arena Global Management Roy Bahadoor, Wiltshire Council